CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-0075:185 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

LISTEE: Fire-Lite Alarms, Inc., One Fire-Lite Place, Northford, CT 06472-1653

Contact: Brian Reynolds (203) 848-6124 Fax (203) 484-7309

DESIGN: Models MDF-300, MMF-301, MMF-300, MMF-302, MCF-300 monitor modules; Models

CRF-300 and CMF-300 control modules; and *MMF-302-6 six zone interface signaling device module. Refer to listee's data sheet for additional detailed product description and

operational considerations.

RATING: 15-32 VDC


INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and

ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, electrical rating, and UL label.

APPROVAL: Listed as control unit accessories for use with listee's separately listed electrically

compatible fire alarm control units.





This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: JANUARY 24, 2003 Listing Expires June 30, 2003

Authorized By: **DIANE K. AREND**, Senior Deputy

Program Manager